

NOTES:

- 1 REVIEW DETAILS AND REVISE AS NEEDED TO SUIT PROJECT REQUIREMENT.
- 2 SIZE CONDENSATE BRANCH LINE NO SMALLER THAN THE TRAP INLET.
- 3 REFER TO LANL FACILITY CONSTRUCTION SPECIFICATIONS SECTIONS 15520 AND 15525.

NO.	DATE	CLASS REV	REVISIONS	APP
FACILITY ENGINEERING MANUAL				
STEAM DRIP LINE				
DESIGN NOTES				
APPROVED: DISCIPLINE POC DANNY NGUYEN			DATE: 6-28-99	
Los Alamos			Los Alamos National Laboratory Los Alamos, New Mexico 87545	
CLASSIFICATION: U			REVIEWER: DANNY NGUYEN	
REFERENCE DOCUMENT:			DRAWING NUMBER:	
CHAPTER 6			ST6203	
			REV	